APPENDIX B

PROPOSED AUTHORITY TO CONSTRUCT ISSUED BY THE SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT

Title Page

Facility I.D.#: 127381
Revision #: DRAFT
Date: April 19, 2001

FACILITY PERMIT TO OPERATE

ALLIANCE POWER INC 661 S COOLEY DR COLTON, KY 42324

NOTICE

IN ACCORDANCE WITH RULE 206, THIS PERMIT TO OPERATE OR A COPY THEREOF MUST BE KEPT AT THE LOCATION FOR WHICH IT IS ISSUED.

THIS PERMIT DOES NOT AUTHORIZE THE EMISSION OF AIR CONTAMINANTS IN EXCESS OF THOSE ALLOWED BY DIVISION 26 OF THE HEALTH AND SAFETY CODE OF THE STATE OF CALIFORNIA OR THE RULES OF THE SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT. THIS PERMIT SHALL NOT BE CONSTRUED AS PERMISSION TO VIOLATE EXISTING LAWS, ORDINANCES, REGULATIONS OR STATUTES OF ANY OTHER FEDERAL, STATE OR LOCAL GOVERNMENTAL AGENCIES.

Barry R. Wallerstein, D. Env.
EXECUTIVE OFFICER
_
Ву
Carol Coy
Deputy Executive Officer
Engineering & Compliance

Table of Content
Facility I.D.#: 127381
Revision #: DRAFT
Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

TABLE OF CONTENTS

Section	Description	Revision #	Date Issued
A	Facility Information	DRAFT	04/19/2001
В	RECLAIM Annual Emission Allocation	DRAFT	04/19/2001
C	Facility Plot Plan	TO BE DEVELO	PED
D	Facility Description and Equipment Specific Conditions	DRAFT	04/19/2001
E	Administrative Conditions	DRAFT	04/19/2001
F	RECLAIM Monitoring and Source Testing Requirements	DRAFT	04/19/2001
G	Recordkeeping and Reporting Requirements for RECLAIM Sources	DRAFT	04/19/2001
Н	Permit To Construct and Temporary Permit to Operate	DRAFT	04/19/2001
I	Compliance Plans & Schedules	DRAFT	04/19/2001
J	Air Toxics	DRAFT	04/19/2001
K	Title V Administration	DRAFT	04/19/2001
Appendix			
A	NOx and SOx Emitting Equipment Exempt From Written Permit Pursuant to Rule 219	DRAFT	04/19/2001
В	Rule Emission Limits	DRAFT	04/19/2001

Section A Page 1 Facility I.D.#: 127381 Revision #: DRAFT Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

SECTION A: FACILITY INFORMATION

LEGAL OWNER &/OR OPERATOR:	ALLIANCE POWER INC
LEGAL OPERATOR (if different than owner):	
EQUIPMENT LOCATION:	661 S COOLEY DR COLTON, KY 42324
MAILING ADDRESS:	7950 S LINCOLN ST SUITE 114 LITTLETON, CO 80122
RESPONSIBLE OFFICIAL:	
TITLE:	
TELEPHONE NUMBER:	
CONTACT PERSON:	BRIAN O'NEILL
TITLE:	VICE PRESIDENT
TELEPHONE NUMBER:	(661) 836-9873

TITLE V	RECLAIM		
YES	NOx:	YES	
	SOx:	NO	
	CYCLE:	1	
	ZONE:	INLAND	

Section C Page 1 Facility I.D.#: 127381 Revision #: DRAFT Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

SECTION C: FACILITY PLOT PLAN

(TO BE DEVELOPED)

Section D Facility I.D.:

Date:

Revision #: DRAFT April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 3: R-219 EXEMPT 1 RULE 219 EXEMPT EQUIPMENT, COATING EQUIPMENT, PORTABLE, ARCHITECTURAL COATINGS	EQUIPM E30	ENT SUBJI	CT TO SOURC	E SPECIFIC RULES ROG: (9) [RULE 1113,5-14- 1999;RULE 1171,6-13-1997;RULE 1171,10-8-1999]	67-2

*	(1)	Denotes RECLAIM emission factor	(2)	Denotes RECLAIM emission rate
	(3)	Denotes RECLAIM concentration limit	(4)	Denotes BACT emission limit
	(5)(5A)(5B)	Denotes command and control emission limit	(6)	Denotes air toxic control rule limit
	(7)	Denotes NSR applicability limit	(8)(8A)(8B)	Denotes 40 CFR limit(e.g. NSPS, NESHAPS, etc.)
	(9)	See App B for Emission Limits	(10)	See Section J for NESHAP/MACT requirements

Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

Section D Page: 2
Facility I.D.: 127381
Revision #: DRAFT
Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

SECTION D: DEVICE ID INDEX

The following sub-section provides an index to the devices that make up the facility description sorted by device ID.

Section D Page: 3
Facility I.D.: 127381
Revision #: DRAFT
Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

SECTION D: DEVICE ID INDEX

Device Index For Section D					
Device ID	Section D Page No.	Process	System		
E30	1	3	0		

Section D Page: 4
Facility I.D.: 127381
Revision #: DRAFT
Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

SECTION D: FACILITY DESCRIPTION AND EQUIPMENT SPECIFIC CONDITIONS

The operator shall comply with the terms and conditions set forth below:

FACILITY CONDITIONS

- F9-1. Except for open abrasive blasting operations, the operator shall not discharge into the atmosphere from any single source of emissions whatsoever any air contaminant for a period or periods aggregating more than three minutes in any one hour which is:
 - (a) As dark or darker in shade as that designated No.1 on the Ringelmann Chart, as published by the United States Bureau of Mines; or
 - (b) Of such opacity as to obscure an observer's view to a degree equal to or greater than does smoke described in subparagraph (a) of this condition.

[RULE 401, 3-2-1984; RULE 401, 9-11-1998]

DEVICE CONDITIONS

67-2. The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

For architectural applications where no thinners, reducers, or other VOC containing materials are added, maintain semi-annual records for all coating consisting of (a) coating type, (b) VOC content as supplied in grams per liter (g/l) of materials for low-solids coatings, (c) VOC content as supplied in g/l of coating, less water and exempt solvent, for other coatings.

For architectural applications where thinners, reducers, or other VOC containing materials are added, maintain daily records for each coating consisting of (a) coating type, (b) VOC content as applied in grams per liter (g/l) of materials used for low-solids coatings, (c) VOC content as applied in g/l of coating, less water and exempt solvent, for other coatings.

[RULE 3004(a)(4)-Periodic Monitoring, 8-11-1995; RULE 3004(a)(4)-Periodic Monitoring, 12-12-1997]

[Devices subject to this condition: E30]

Section E Page Facility I.D.#: 127381
Revision #: DRAFT
Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

SECTION E: ADMINISTRATIVE CONDITIONS

The operating conditions in this section shall apply to all permitted equipment at this facility unless superseded by condition(s) listed elsewhere in this permit.

- 1. The permit shall remain effective unless this permit is suspended, revoked, modified, reissued, denied, or it is expired for nonpayment of permit processing or annual operating fees. [201, 203, 209, 301]
 - a. The permit must be renewed annually by paying annual operating fees, and the permit shall expire if annual operating fees are not paid pursuant to requirements of Rule 301(d). [301(d)]
 - b. The Permit to Construct listed in Section H shall expire one year from the Permit to Construct issuance date, unless a Permit to Construct extension has been granted by the Executive Officer or unless the equipment has been constructed and the operator has notified the Executive Officer prior to the operation of the equipment, in which case the Permit to Construct serves as a temporary Permit to Operate. [202, 205]
 - c. The Title V permit shall expire as specified under Section K of the Title V permit. The permit expiration date of the Title V facility permit does not supercede the requirements of Rule 205. [205, 3004]
- 2. The operator shall maintain all equipment in such a manner that ensures proper operation of the equipment. [204]
- 3. This permit does not authorize the emissions of air contaminants in excess of those allowed by Division 26 of the Health and Safety Code of the State of California or the Rules and Regulations of the AQMD. This permit cannot be considered as permission to violate existing laws, ordinances, regulations, or statutes of other governmental agencies. [204]
- 4. The operator shall not use equipment identified in this facility permit as being connected to air pollution control equipment unless they are so vented to the identified air pollution control equipment which is in full use and which has been included in this permit. [204]
- 5. The operator shall not use any equipment having air pollution control device(s) incorporated within the equipment unless the air pollution control device is in full operation. [204]
- 6. The operator shall maintain records to demonstrate compliance with rules or permit conditions that limit equipment operating parameters, or the type or quantity of material processed. These records shall be made available to AQMD personnel upon request and be maintained for at least: [204]

Section E Page 2 Facility I.D.#: 127381 Revision #: DRAFT Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

SECTION E: ADMINISTRATIVE CONDITIONS

- a. Three years for a facility not subject to Title V; or
- b. Five years for a facility subject to Title V.
- 7. The operator shall maintain and operate all equipment to ensure compliance with all emission limits as specified in this facility permit. Compliance with emission limits shall be determined according to the following specifications, unless otherwise specified by AQMD rules or permit conditions: [204]
 - a. For internal combustion engines and gas turbines, measured concentrations shall be corrected to 15 percent stack-gas oxygen content on a dry basis and be averaged over a period of 15 consecutive minutes; [1110.2, 1134, 204]
 - b. For other combustion devices, measured concentrations shall be corrected to 3 percent stack-gas oxygen content on a dry basis and be averaged over a period of 15 consecutive minutes; [1146, 1146.1, 204]
 - c. For a large NOx source, compliance with a RECLAIM concentration limit shall be measured over a continuous 60 minutes for that source; [2012]
 - d. For non-combustion sources, compliance with emission limits shall be determined and averaged over a period of 60 minutes; [204]
 - e. For the purpose of determining compliance with Rule 407, carbon monoxide (CO) shall be measured on a dry basis and be averaged over 15 consecutive minutes, and sulfur compounds which would exist as liquid or gas at standard conditions shall be calculated as sulfur dioxide (SO2) and be averaged over 15 consecutive minutes; [407]
 - f. For the purpose of determining compliance with Rule 409, combustion contaminant emission measurements shall be corrected to 12 percent of carbon dioxide (CO2) at standard conditions and averaged over 15 consecutive minutes. [409]
 - g. For the purpose of determining compliance with Rule 475, combustion contaminant emission measurements shall be corrected to 3 percent of oxygen (O2) at standard conditions and averaged over 15 consecutive minutes or any other averaging time specified by the Executive Officer. [475]
- 8. All equipment operating under the RECLAIM program shall comply concurrently with all provisions of AQMD Rules and Regulation, except those listed in Table 1 of Rule 2001 for NOx RECLAIM sources and Table 2 of Rule 2001 for SOx RECLAIM sources. Those provisions listed in Tables 1 or 2 shall not apply to NOx or SOx emissions after the date the facility has demonstrated compliance with all monitoring and reporting requirements of Rules 2011 or 2012, as applicable. Provisions of the listed AQMD rules in Tables 1 or 2 which have initial implementation dates in 1994 shall not apply to a RECLAIM NOx or SOx source, respectively. [2001]

Section E Page 3 Facility I.D.#: 127381 Revision #: DRAFT Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

SECTION E: ADMINISTRATIVE CONDITIONS

- 9. The operator shall, when a source test is required by AQMD, provide a source test protocol to AQMD no later than 60 days before the proposed test date. The test shall not commence until the protocol is approved by AQMD. The test protocol shall contain the following information: [204, 304]
 - a. Brief description of the equipment tested.
 - b. Brief process description, including maximum and normal operating temperatures, pressures, through-put, etc.
 - c. Operating conditions under which the test will be performed.
 - d. Method of measuring operating parameters, such as fuel rate and process weight. Process schematic diagram showing the ports and sampling locations, including the dimensions of the ducts/stacks at the sampling locations, and distances of flow disturbances, (e,g. elbows, tees, fans, dampers) from the sampling locations (upstream and downstream).
 - e. Brief description of sampling and analytical methods used to measure each pollutant, temperature, flow rates, and moisture.
 - f. Description of calibration and quality assurance procedures.
 - g. Determination that the testing laboratory qualifies as an "independent testing laboratory" under Rule 304 (no conflict of interest).
- 10. The operator shall submit a report no later than 60 days after conducting a source test, unless otherwise required by AQMD Rules or equipment-specific conditions. The report shall contain the following information: [204]
 - a. The results of the source test.
 - b. Brief description of the equipment tested.
 - c. Operating conditions under which test will be performed.
 - d. Method of measuring operating parameters, such as fuel rate and process weight. Process schematic diagram showing the ports and sampling locations, including the dimensions of the ducts/stacks at the sampling locations, and distances of flow disturbances, (e.g. elbows, tees, fans, dampers) from the sampling locations (upstream and downstream).
 - e. Field and laboratory data forms, strip charts and analyses.
 - f. Calculations for volumetric flow rates, emission rates, control efficiency, and overall control efficiency.
- The operator shall, when a source test is required, provide and maintain facilities for sampling and testing. These facilities shall comply with the requirements of AQMD Source Test Method 1.1 and 1.2. [217]

Section E Page 4 Facility I.D.#: 127381 Revision #: DRAFT Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

SECTION E: ADMINISTRATIVE CONDITIONS

Whenever required to submit a written report, notification or other submittal to the Executive Officer, AQMD, or the District, the operator shall mail or deliver the material to: Deputy Executive Officer, Engineering and Compliance, AQMD, 21865 E. Copley Drive, Diamond Bar, CA 91765-4182. [204]

Section F Page 1 Facility I.D.#: 127381 Revision #: DRAFT Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

SECTION F: RECLAIM MONITORING AND SOURCE TESTING REQUIREMENTS

The Facility shall comply with all applicable monitoring and source testing requirements in Regulation XX. These requirements may include but are not limited to the following:

I. NOx Monitoring Conditions

- A. The Operator of a NOx Major Source, as defined in Rule 2012, shall, as applicable:
- 1. Install, maintain, and operate an AQMD certified direct or time-shared monitoring device or an approved alternative monitoring device for each major NOx source to continuously measure the concentration of NOx emissions and all other applicable variables specified in Rule 2012, Table 2012-1 and Rule 2012, Appendix A, Table 2-A to determine the NOx emissions rate from each source. The time-sharing of CEMS among NOx sources may be allowed by the Executive Officer in accordance with the requirements for time sharing specified in Appendix A. [2012]
- 2. Install, maintain, and operate a totalizing fuel meter approved by the Executive Officer for each major source. [2012]
- 3. If the facility is operating existing CEMS and fuel meters, continue to follow recording and reporting procedures required by AQMD Rules and Regulations in effect prior to October 15, 1993 until the CEMS is certified pursuant to Rule 2012. [2012]
- 4. Use valid data collected by an AQMD certified or provisionally certified CEMS in proper operation that meets all the requirements of Appendix A of Rule 2012, unless final certification of the CEMS is denied, to determine mass emissions for all purposes, including, but not limited to, determining: [2012]
 - a. compliance with the annual Allocation;
 - b. excess emissions;
 - c. the amount of penalties; and
 - d. fees.
- 5. Follow missing data procedures as specified in Rule 2012 Appendix A whenever valid data is not available or collected to determine mass emissions for all purposes, including, but not limited to, determining: [2012]
 - a. compliance with the annual Allocation;
 - b. excess emissions:
 - c. the amount of penalties; and
 - d. fees.

Section F Page 2 Facility I.D.#: 127381 Revision #: DRAFT Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

SECTION F: RECLAIM MONITORING AND SOURCE TESTING REQUIREMENTS

- B. The Operator of a NOx Large Source, as defined in Rule 2012, shall, as applicable:
 Not Applicable
- C. The Operator of a NOx Process Unit, as defined in Rule 2012, shall, as applicable:

 Not Applicable
- II. NOx Source Testing and Tune-up Conditions
 - 1. The operator shall conduct all required NOx source testing in compliance with an AQMD-approved source test protocol. [2012]
 - 2. The operator shall, as applicable, conduct source tests for every large NOx source no later than December 31, 1996 and every 3 years thereafter. The source test shall include the determination of NOx concentration and a relative accuracy audit of the exhaust stack flow determination (e.g. in-stack flow monitor or fuel flow monitor based F-factor calculation). Such source test results shall be submitted per the schedule described by APEP. In lieu of submitting the first source test report, the facility permit holder may submit the results of a source test not more than 3 years old which meets the requirements when conducted. [2012]
 - 3. All NOx large sources and NOx process units shall be tuned-up in accordance with the schedule specified in Rule 2012, Appendix A, Chapter 5, Table 5-B. [2012]

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

SECTION G: RECORDKEEPING AND REPORTING REQUIREMENTS FOR RECLAIM SOURCES

The Facility shall comply with all applicable reporting and recordkeeping requirements in Regulation XX. These requirements may include but are not limited to the following:

- I. Recordkeeping Requirements for all RECLAIM Sources
 - 1. The operator shall maintain all monitoring data required to be measured or reported pursuant to Rule 2011 and Rule 2012, whichever is applicable. All records shall be made available to AQMD staff upon request and be maintained for at least:
 - a. Three years after each APEP report is submitted to AQMD for a facility not subject to Title V, unless a different time period is required in Rule 2011 or Rule 2012 [2011 & 2012]; or
 - b. Five years after each APEP report is submitted to AQMD for a facility subject to Title V. [3004(a)(4)(E)]
 - c. Notwithstanding the above, all data gathered or computed for intervals of less than 15 minutes shall only be maintained a minimum of 48 hours. [2011 & 2012]
 - 2. The operator shall store on site and make available to the Executive Officer upon request, records used to determine emissions, maintenance records, sources test reports, relative accuracy test audit reports, relative accuracy audit reports and fuel meter calibration records. [2011 & 2012]

II. Reporting Requirements for all RECLAIM Sources

1. The operator shall submit a quarterly certification of emissions including the facility's total NOx or SOx emissions, whichever is applicable, for the quarter within 30 days after the end of the first three quarters and 60 days after the end of the fourth quarter of a compliance year. [2011 & 2012]

NOx Reporting Requirements

- A. The Operator of a NOx Major Source, as defined in Rule 2012, shall, as applicable:
- 1. No later than 12 months after entry into the RECLAIM program or after the initial operation of a new major source, whichever is later, install, maintain, and operate a reporting device to electronically report everyday to the AQMD central station for each major NOx source, the total daily mass emissions of NOx and daily status codes. Such data

Section G Page 2
Facility I.D.#: 127381
Revision #: DRAFT
Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

SECTION G: RECORDKEEPING AND REPORTING REQUIREMENTS FOR RECLAIM SOURCES

shall be transmitted by 5:00 p.m. of the following day. If the facility experiences a power, computer, or other system failure that prevents the submittal of the daily report, the Facility Permit holder shall be granted 24 hours extension to submit the report. [2012]

- 2. Calculate NOx emissions pursuant to missing data procedures set forth in Appendix A, Chapter 2 of Rule 2012 if the Facility Permit holder fails to meet the deadline for submitting the daily report. [2012]
- 3. Submit an electronic report within 15 days following the end of each month totaling NOX emissions from all major NOx sources during the month. [2012]
- 4. For those facilities with existing CEMS and fuel meters as of October 15, 1993, continue to follow recording and reporting procedures required by AQMD Rules and Regulations in effect until the CEMS is certified pursuant to Rule 2011 and/or Rule 2012, as applicable. [2012]
- B. The Operator of a NOx Large Source, as defined in Rule 2012, shall:

Not Applicable

C. The Operator of NOx Process Units, as defined in Rule 2012, shall:

Not Applicable

Section H Page: 1 Facility I.D.: 127381 Revision #: DRAFT Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : INTERNAL CO	MBUSTI	ON			
System 1 : POWER GENER	RATION,	UNIT NO. 1			
TURBINE, NO.1, NATURAL GAS, GENERAL ELECTRIC, MODEL 10B1, SIMPLE CYCLE, 116.3 MMBTU/HR WITH A/N:	DI	C4 C5	NOX: MAJOR SOURCE**	CO: 6 PPMV (4) [RULE 1303(a)(1)-BACT,5-10-1996;RULE 1303(a)(1)-BACT,10-20-2000]; CO: 2000 PPMV (5) [RULE 407,4-2-1982]	1-1, 12-1, 12-2, 28-1, 40-1, 57-1, 63-1, 67-1, 73-1, 82-1, 82-2, 99-1, 99-2, 99-3, 195- 1, 195-2, 327-1, 419-1
				NOX: 195.58 LBS/MMCF NATURAL GAS (1) [RULE 2012,12-7-1995; RULE 2012,3-16- 2001]; NOX: 98.05 LBS/MMCF (1) [RULE 2012,12-7-1995	
				RULE 2012,3-16-2001]; NOX: 5 PPMV (4) [RULE 2005,4-9- 1999]; NOX: 92 PPMV (8) [40CFR 60 Subpart GG,3-6-1981]	
				PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981;RULE 475,10-8-1976;RULE 475,8-7-1978] ; PM: 11 LBS/HR (5) [RULE 409,8-7-1981	
				RULE 475,10-8-1976; <i>RULE</i> 475,8-7-1978]; PM: 0.01 GRAINS/SCF (5A) [RULE 475,10-8-1976; <i>RULE</i> 475,8-7-1978]	
	·			SOX: 150 PPMV (8) [40CFR 60 Subpart GG,3-6-1981]; VOC: 2 PPMV (4) [RULE 1303(a)(1)- BACT,5-10-1996	

*	(1)	Denotes RECLAIM emission factor	(2)	Denotes RECLAIM emission rate
	(3)	Denotes RECLAIM concentration limit	(4)	Denotes BACT emission limit
	(5)(5A)(5B)Denotes command and control emission limit	(6)	Denotes air toxic control rule limit
	(7)	Denotes NSR applicability limit	(8)(8A)(8B	Denotes 40 CFR limit(e.g. NSPS, NESHAPS, etc.)
	(9)	See App B for Emission Limits	(10)	See Section J for NESHAP/MACT requirements

^{**} Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

Section H Page: 2
Facility I.D.: 127381
Revision #: DRAFT
Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : INTERNAL CON	MBUSTI	ON			
			,	RULE 1303(a)(1)-BACT,10-20- 2000]	
COMBUSTOR, XONON				; 	:
GENERATOR, NO. 1, 10.5 MW		į			
CO OXIDATION CATALYST, NO. 1, SERVING GAS TURBINE NO. 1, HUNTINGTON ENVIRONMENTAL SYSTEM, PRECIOUS METAL (PD, PT) ON METAL FOIL, WITH 40-50 CUBIC FEET OF TOTAL CATALYST VOLUME, 22 FT H X 13.5 FT L X 10.5 A/N:	C4	D1 C5			<u> </u>
SELECTIVE CATALYTIC REDUCTION, NO.1 SERVING GAS TURBINE NO. 1, HUNTINGTON ENVIRONMENTAL, MONO-NOX VANADIA/TITANNNIA 275 CUBIC FEET, HEIGHT: 22 FT; LENGTH: 13 FT 6 IN; WIDTH: 10 FT 6 IN WITH A/N:	C5	D1 C4		NH3: 5 PPMV (4) [RULE 1303(a)(1)-BACT,5-10-1996;RULE 1303(a)(1)-BACT,10-20-2000]	12-3, 12-4, 12-5, 28-2, 179-1, 179-2, 195-3
AMMONIA INJECTION	,			1	!
STACK, NO. 1 A/N:	S 7				

*	(1)	Denotes RECLAIM emission factor	(2)	Denotes RECLAIM emission rate
	(3)	Denotes RECLAIM concentration limit	(4)	Denotes BACT emission limit
	(5)(5A)(5B)Denotes command and control emission limit	(6)	Denotes air toxic control rule limit
	(7)	Denotes NSR applicability limit	(8)(8A)(8B	Denotes 40 CFR limit(e.g. NSPS, NESHAPS, etc.)
	(9)	See App B for Emission Limits	(10)	See Section J for NESHAP/MACT requirements

^{**} Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

Section H Page: 3
Facility I.D.: 127381
Revision #: DRAFT
Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : INTERNAL CO	MBUSTI	ON		***	
System 2: POWER GENER	CATION,	UNIT NO. 2	}		
TURBINE, NO.2, NATURAL GAS, GENERAL ELECTRIC, MODEL 10B1, SIMPLE CYCLE, 116.3 MMBTU/HR WITH A/N:	D8	C11 C12	NOX: MAJOR SOURCE**	CO: 6 PPMV (4) [RULE 1303(a)(1)-BACT,5-10-1996; RULE 1303(a)(1)-BACT,10-20-2000]; CO: 2000 PPMV (5) [RULE 407,4-2-1982]	1-1, 12-1, 12-2, 28-1, 40-1, 57-1, 63-1, 67-1, 73-1, 82-1, 82-2, 99-1, 99-2, 99-3, 195- 1, 195-2, 327-1, 419-1
			: i	NOX: 195.58 LBS/MMCF NATURAL GAS (1) [RULE 2012,12-7-1995; RULE 2012,3-16- 2001]; NOX: 98.05 LBS/MMCF (1) [RULE 2012,12-7-1995	
				RULE 2012,3-16-2001]; NOX: 5 PPMV (4) [RULE 2005,4-9-1999]; NOX: 92 PPMV (8) [40CFR 60 Subpart GG,3-6-1981]	
				PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981;RULE 475,10-8-1976;RULE 475,8-7-1978] ; PM: 11 LBS/HR (5) [RULE 409,8-7-1981	
				RULE 475,10-8-1976; RULE 475,8-7-1978]; PM: 0.01 GRAINS/SCF (5A) [RULE 475,10-8-1976; RULE 475,8-7-1978]	!

*	(1)	Denotes RECLAIM emission factor	(2)	Denotes RECLAIM emission rate
	(3)	Denotes RECLAIM concentration limit	(4)	Denotes BACT emission limit
	(5)(5A)(5B)	Denotes command and control emission limit	(6)	Denotes air toxic control rule limit
	(7)	Denotes NSR applicability limit	(8)(8A)(8B)	Denotes 40 CFR limit(e.g. NSPS, NESHAPS,etc.)
	(9)	See App B for Emission Limits	(10)	See Section J for NESHAP/MACT requirements

^{**} Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

Section H Page: 4
Facility I.D.: 127381
Revision #: DRAFT
Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : INTERNAL CON	1BUSTI	ON			
				SOX: 150 PPMV (8) [40CFR 60 Subpart GG,3-6-1981]; VOC: 2 PPMV (4) [RULE 1303(a)(1)- BACT,5-10-1996	
	•			RULE 1303(a)(1)-BACT,10-20- 2000]	
COMBUSTOR, XONON					:
GENERATOR, NO. 2, 10.5 MW			!	: 	: !
CO OXIDATION CATALYST, NO. 2, SERVING GAS TURBINE NO. 2, HUNTINGTON ENVIRONMENTAL SYSTEM, PRECIOUS METAL (PD, PT) ON METAL FOIL, WITH 40-50 CUBIC FEET OF TOTAL CATALYST VOLUME, 22 FT H X 13.5 FT L X 10.5 A/N:	C11	D8 C12			
SELECTIVE CATALYTIC REDUCTION, NO.2 SERVING GAS TURBINE NO. 2, HUNTINGTON ENVIRONMENTAL, MONO-NOX VANADIA/TITANNNIA 275 CUBIC FEET, HEIGHT: 22 FT; LENGTH: 13 FT 6 IN; WIDTH: 10 FT 6 IN WITH A/N:	C12	D8 C11		NH3: 5 PPMV (4) {RULE 1303(a)(1)-BACT,5-10-1996;RULE 1303(a)(1)-BACT,10-20-2000]	12-3, 12-4, 12-5, 28-2, 179-1, 179-2, 195-3
AMMONIA INJECTION		i			

*	(1)	Denotes RECLAIM emission factor	(2)	Denotes RECLAIM emission rate
	(3)	Denotes RECLAIM concentration limit	(4)	Denotes BACT emission limit
	(5)(5A)(5B)	Denotes command and control emission limit	(6)	Denotes air toxic control rule limit
	(7)	Denotes NSR applicability limit	(8)(8A)(8B	Denotes 40 CFR limit(e.g. NSPS, NESHAPS,etc.)
	(9)	See App B for Emission Limits	(10)	See Section J for NESHAP/MACT requirements

^{**} Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

Section H Page: 5
Facility I.D.: 127381
Revision #: DRAFT
Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : INTERNAL CO	MBUSTI	ON			
STACK, NO. 2 A/N:	S14				
System 3: POWER GENER	RATION,	UNIT NO. 3			
TURBINE, NO.3, NATURAL GAS, GENERAL ELECTRIC, MODEL 10B1, SIMPLE CYCLE, 116.3 MMBTU/HR WITH A/N:	D15	C18 C19	NOX: MAJOR SOURCE**	CO: 6 PPMV (4) [RULE 1303(a)(1)-BACT,5-10-1996;RULE 1303(a)(1)-BACT,10-20-2000]; CO: 2000 PPMV (5) [RULE 407,4-2-1982]	1-1, 12-1, 12-2, 28-1, 40-1, 57-1 63-1, 67-1, 73-1 82-1, 82-2, 99-1 99-2, 99-3, 195- 1, 195-2, 327-1, 419-1
				NOX: 195.58 LBS/MMCF NATURAL GAS (1) [RULE 2012,12-7-1995; RULE 2012,3-16- 2001]; NOX: 98.05 LBS/MMCF (1) [RULE 2012,12-7-1995	
				RULE 2012,3-16-2001]; NOX: 5 PPMV (4) [RULE 2005,4-9-1999]; NOX: 92 PPMV (8) [40CFR 60 Subpart GG,3-6-1981]	
				PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981;RULE 475,10-8-1976;RULE 475,8-7-1978] ; PM: 11 LBS/HR (5) [RULE 409,8-7-1981	
				RULE 475,10-8-1976; RULE 475,8-7-1978]; PM: 0.01 GRAINS/SCF (5A) [RULE 475,10-8-1976; RULE 475,8-7-1978]	

				•
*	(1)	Denotes RECLAIM emission factor	(2)	Denotes RECLAIM emission rate
	(3)	Denotes RECLAIM concentration limit	(4)	Denotes BACT emission limit
	(5)(5A)(5B)	Denotes command and control emission limit	(6)	Denotes air toxic control rule limit
	(7)	Denotes NSR applicability limit	(8)(8A)(8B)	Denotes 40 CFR limit(e.g. NSPS, NESHAPS, etc.)
	(9)	See App B for Emission Limits	(10)	See Section J for NESHAP/MACT requirements

^{**} Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

Section H Page: 6
Facility I.D.: 127381
Revision #: DRAFT
Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : INTERNAL COM	ABUSTI	ON			
				SOX: 150 PPMV (8) [40CFR 60 Subpart GG,3-6-1981]; VOC: 2 PPMV (4) [RULE 1303(a)(1)- BACT,5-10-1996 RULE 1303(a)(1)-BACT,10-20- 2000]	
COMBUSTOR, XONON					
GENERATOR, NO. 3, 10.5 MW	! !				
CO OXIDATION CATALYST, NO. 3, SERVING GAS TURBINE NO. 3, HUNTINGTON ENVIRONMENTAL SYSTEM, PRECIOUS METAL (PD, PT) ON METAL FOIL, WITH 40-50 CUBIC FEET OF TOTAL CATALYST VOLUME, 22 FT H X 13.5 FT L X 10.5 A/N:	C18	D15 C19			
SELECTIVE CATALYTIC REDUCTION, NO.3 SERVING GAS TURBINE NO. 3, HUNTINGTON ENVIRONMENTAL, MONO-NOX VANADIA/TITANNNIA 275 CUBIC FEET, HEIGHT: 22 FT; LENGTH: 13 FT 6 IN; WIDTH: 10 FT 6 IN WITH A/N:	C19	D15 C18		NH3: 5 PPMV (4) [RULE 1303(a)(1)-BACT,5-10-1996;RULE 1303(a)(1)-BACT,10-20-2000]	12-3, 12-4, 12-5 28-2, 179-1, 179-2, 195-3
AMMONIA INJECTION		<u> </u>		 	

*	(1)	Denotes RECLAIM emission factor	(2)	Denotes RECLAIM emission rate
	(3)	Denotes RECLAIM concentration limit	(4)	Denotes BACT emission limit
	(5)(5A)(5I	3) Denotes command and control emission limit	(6)	Denotes air toxic control rule limit
	(7)	Denotes NSR applicability limit	(8)(8A)(8B	Denotes 40 CFR limit(e.g. NSPS, NESHAPS,etc.)
	(9)	See App B for Emission Limits	(10)	See Section J for NESHAP/MACT requirements

^{**} Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

Section H Page: 7
Facility I.D.: 127381
Revision #: DRAFT
Date: April 19, 2001

FACILITY PERMIT TO OPERATE **ALLIANCE POWER INC**

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : INTERNAL CO	MBUSTI	ON			
STACK, NO. 3 A/N:	S21				
System 4: POWER GENER	CATION,	UNIT NO. 4			
TURBINE, NO.4, NATURAL GAS, GENERAL ELECTRIC, MODEL 10B1, SIMPLE CYCLE, 116.3 MMBTU/HR WITH A/N:	D22	C25 C26	NOX: MAJOR SOURCE**	CO: 6 PPMV (4) [RULE 1303(a)(1)-BACT,5-10-1996; RULE 1303(a)(1)-BACT,10-20-2000]; CO: 2000 PPMV (5) [RULE 407,4-2-1982]	1-1, 12-1, 12-2, 28-1, 40-1, 57-1, 63-1, 67-1, 73-1, 82-1, 82-2, 99-1, 99-2, 99-3, 195- 1, 195-2, 327-1, 419-1
				NOX: 195.58 LBS/MMCF NATURAL GAS (1) [RULE 2012,12-7-1995; RULE 2012,3-16- 2001]; NOX: 98.05 LBS/MMCF (1) [RULE 2012,12-7-1995	
			:	RULE 2012,3-16-2001]; NOX: 5 PPMV (4) [RULE 2005,4-9-1999]; NOX: 92 PPMV (8) [40CFR 60 Subpart GG,3-6-1981]	
				PM: 0.1 GRAINS/SCF (5) [RULE 409,8-7-1981;RULE 475,10-8-1976;RULE 475,8-7-1978] ; PM: 11 LBS/HR (5) [RULE 409,8-7-1981	
				RULE 475,10-8-1976; RULE 475,8-7-1978]; PM: 0.01 GRAINS/SCF (5A) [RULE 475,10-8-1976; RULE 475,8-7-1978]	

*	(1)	Denotes RECLAIM emission factor	(2)	Denotes RECLAIM emission rate
	(3)	Denotes RECLAIM concentration limit	(4)	Denotes BACT emission limit
	(5)(5A)(5E	Denotes command and control emission limit	(6)	Denotes air toxic control rule limit
	(7)	Denotes NSR applicability limit	(8)(8A)(8B)	Denotes 40 CFR limit(e.g. NSPS, NESHAPS, etc.)
	(9)	See App B for Emission Limits	(10)	See Section J for NESHAP/MACT requirements

^{**} Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

Section H Page: 8
Facility I.D.: 127381
Revision #: DRAFT
Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1: INTERNAL COM	ивиstі	ON			
		:		SOX: 150 PPMV (8) [40CFR 60 Subpart GG,3-6-1981]; VOC: 2 PPMV (4) [RULE 1303(a)(1)- BACT,5-10-1996 RULE 1303(a)(1)-BACT,10-20- 2000]	
COMBUSTOR, XONON	•				
GENERATOR, NO. 4, 10.5 MW					:
CO OXIDATION CATALYST, NO. 4, SERVING GAS TURBINE NO. 4, HUNTINGTON ENVIRONMENTAL SYSTEM, PRECIOUS METAL (PD, PT) ON METAL FOIL, WITH 40-50 CUBIC FEET OF TOTAL CATALYST VOLUME, 22 FT H X 13.5 FT L X 10.5 A/N:	C25	D22 C26			
SELECTIVE CATALYTIC REDUCTION, NO.4 SERVING GAS TURBINE NO. 4, HUNTINGTON ENVIRONMENTAL, MONO-NOX VANADIA/TITANNNIA 275 CUBIC FEET, HEIGHT: 22 FT; LENGTH: 13 FT 6 IN; WIDTH: 10 FT 6 IN WITH A/N: AMMONIA INJECTION	C26	D22 C25		NH3: 5 PPMV (4) [RULE 1303(a)(1)-BACT,5-10-1996;RULE 1303(a)(1)-BACT,10-20-2000]	12-3, 12-4, 12-5, 28-2, 179-1, 179-2, 195-3

*	(1)	Denotes RECLAIM emission factor	(2)	Denotes RECLAIM emission rate
	(3)	Denotes RECLAIM concentration limit	(4)	Denotes BACT emission limit
	(5)(5A)(5B	Denotes command and control emission limit	(6)	Denotes air toxic control rule limit
	(7)	Denotes NSR applicability limit	(8)(8A)(8B	Denotes 40 CFR limit(e.g. NSPS, NESHAPS,etc.)
	(9)	See App B for Emission Limits	(10)	See Section J for NESHAP/MACT requirements

^{**} Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

Section H Page: 9
Facility I.D.: 127381
Revision #: DRAFT
Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

Equipment	ID No.	Connected To	RECLAIM Source Type/ Monitoring Unit	Emissions * And Requirements	Conditions
Process 1 : INTERNAL CO	MBUSTI	ON			
STACK, NO. 4 A/N:	S28				
Process 2 : INORGANIC CI	HEMICA	L STORAGE)		
STORAGE TANK, FIXED ROOF, AQUEOUS AMMONIA 19% SOLUTION, WITH VAPOR RETURN LINE, 10000 GALS A/N:	D29				144-1, 157-1

*	(1)	Denotes RECLAIM emission factor	(2)	Denotes RECLAIM emission rate
	(3)	Denotes RECLAIM concentration limit	(4)	Denotes BACT emission limit
	(5)(5A)(5B)	Denotes command and control emission limit	(6)	Denotes air toxic control rule limit
	(7)	Denotes NSR applicability limit	(8)(8A)(8B)	Denotes 40 CFR limit(e.g. NSPS, NESHAPS, etc.)
	(9)	See App B for Emission Limits	(10)	See Section J for NESHAP/MACT requirements

^{**} Refer to Section F and G of this permit to determine the monitoring, recordkeeping and reporting requirements for this device.

Section H Page: 10
Facility I.D.: 127381
Revision #: DRAFT
Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

SECTION H: DEVICE ID INDEX

The following sub-section provides an index to the devices that make up the facility description sorted by device ID.

Section H Page: 11
Facility I.D.: 127381
Revision #: DRAFT
Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

SECTION H: DEVICE ID INDEX

Device Index For Section H					
Device ID	Section H Page No.	Process	System		
D1	1	1	1		
C4	2	1	1		
C5	2	1	1		
S7	2	1	1		
D8	3	1	2		
C11	4	1	2		
C12	4	1	2		
S14	5	1	2		
D15	5	1	3		
C18	6	1	3		
C19	6	1	3		
S21	7	1	3		
D22	7	1	4		
C25	8	1	4		
C26	8	1	4		
S28	9	1	4		
D29	9	2	0		

Section H Page: 12
Facility I.D.: 127381
Revision #: DRAFT
Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

FACILITY CONDITIONS

- F9-1. Except for open abrasive blasting operations, the operator shall not discharge into the atmosphere from any single source of emissions whatsoever any air contaminant for a period or periods aggregating more than three minutes in any one hour which is:
 - (a) As dark or darker in shade as that designated No.1 on the Ringelmann Chart, as published by the United States Bureau of Mines; or
 - (b) Of such opacity as to obscure an observer's view to a degree equal to or greater than does smoke described in subparagraph (a) of this condition.

[RULE 401, 3-2-1984; RULE 401, 9-11-1998]

DEVICE CONDITIONS

1-1. The operator shall limit the operating time to no more than 2415 hour(s) in any one year.

The operator shall maintain records in a manner approved by the District, to demonstrate compliance with this condition.

[RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 10-20-2000]

[Devices subject to this condition: D1, D8, D15, D22]

12-1. The operator shall install and maintain a(n) non-resettable elapsed time meter to accurately indicate the elapsed operating time of the turbine.

[RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 10-20-2000]

Section H Page: 13 Facility I.D.: 127381 Revision #: DRAFT Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

12-2. The operator shall install and maintain a(n) non-resettable totalizing fuel flow meter to accurately indicate the fuel usage being supplied to the turbine.

[RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 10-20-2000]

[Devices subject to this condition: D1, D8, D15, D22]

12-3. The operator shall install and maintain a(n) flow meter to accurately indicate the flow rate of the total hourly throughput of injected ammonia (NH3).

The operator shall also install and maintain a device to continuously record the parameter being measured.

The measuring device or gauge shall be accurate to within plus or minus 5 percent. It shall be calibrated once every 12 months.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 10-20-2000]

[Devices subject to this condition: C5, C12, C19, C26]

12-4. The operator shall install and maintain a(n) temperature gauge to accurately indicate the temperature of the exhaust at the inlet to the SCR reactor.

The operator shall also install and maintain a device to continuously record the parameter being measured.

The measuring device or gauge shall be accurate to within plus or minus 5 percent. It shall be calibrated once every 12 months.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 10-20-2000; RULE 2005, 4-9-1999]

[Devices subject to this condition: C5, C12, C19, C26]

Section H Page: 14
Facility I.D.: 127381
Revision #: DRAFT
Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

12-5. The operator shall install and maintain a(n) pressure gauge to accurately indicate the pressure across the SCR catalyst bed in inches of water column.

The operator shall also install and maintain a device to continuously record the parameter being measured.

The measuring device or gauge shall be accurate to within plus or minus 5 percent. It shall be calibrated once every 12 months.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 10-20-2000]

[Devices subject to this condition: C5, C12, C19, C26]

Section H Page: 15
Facility I.D.: 127381
Revision #: DRAFT
Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

28-1. The operator shall conduct source test(s) in accordance with the following specifications:

The test shall be conducted to determine the CO emissions using District method 100.1 measured over a 60 minute averaging time period.

The test shall be conducted to determine the NOX emissions using District method 100.1 measured over a 60 minute averaging time period.

The test shall be conducted to determine the PM emissions using District method 5.2 measured over a 60 minute averaging time period.

The test shall be conducted to determine the ROG emissions using approved District method measured over a 60 minute averaging time period.

The test shall be conducted to determine the SOX emissions using District method 6.1 measured over a 60 minute averaging time period.

The District shall be notified of the date and time of the test at least 10 days prior to the test.

The test shall be conducted to determine the NH3 emissions using District Methods 207.1 and 5.3 or EPA method 17 measured over a 60 minute averaging period.

The test shall be conducted the oxygen levels in the exhaust. In addition, the test shall measure fuel flow rate (CFH), the flue gas rate, the flue gas temperature, and the generator power output (MW).

The test shall be conducted in accordance with a District approved source test protocol. The protocol shall be submitted to the District engineer no later than 45 days before the proposed test date and shall be approved by the District before the test commences. The test protocol shall include the proposed operating conditions of the turbine during the test, the identity of the testing lab, a statement from the testing lab certifying that it meets the criteria of R304, and a description of all sampling and analytical procedures.

The test shall be conducted after approval of the source test protocol but no later than 180 days after initial start up.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 10-20-2000; RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 10-20-2000; RULE 2005, 4-9-1999]

Section H Page: 16
Facility I.D.: 127381
Revision #: DRAFT
Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

28-2. The operator shall conduct source test(s) in accordance with the following specifications:

The District shall be notified of the date and time of the test at least 7 days prior to the test.

The test shall be conducted to demonstrate compliance with the Rule 1303 concentration limit.

The test shall be conducted and the results submitted to the District within 45 days after the test date.

The test shall be conducted to determine the NH3 emissions using District Method 207.1 and 5.3 or EPA Method 17 measured over a 60-minute averaging time period. The NOx concentration, as determined by reading the CEMS, shall be simultaneously recorded during the test. If the CEMS is inoperable, a test shall be conducted to determine the NOx emissions using District Method 100.1 measured over a 60-minute averaging time period.

The test shall be conducted at least quarterly during the first twelve months of operation and at least annually thereafter.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 10-20-2000]

[Devices subject to this condition: C5, C12, C19, C26]

Section H Page: 17
Facility I.D.: 127381
Revision #: DRAFT
Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

40-1. The operator shall provide to the District a source test report in accordance with the following specifications:

Source test results shall be submitted to the District no later than 60 days after the source test was conducted.

Emission data shall be expressed in terms of concentration (ppmv), corrected to 15 percent oxygen, dry basis.

All exhaust flow rate shall be expressed in terms of dry standard cubic feet per minute (DSCFM) and dry actual cubic feet per minute (DACFM).

All moisture concentration shall be expressed in terms of percent corrected to 15 percent oxygen, dry basis.

Emission data shall be expressed in terms of mass rate (lbs/hr). In addition, solid PM emissions, if required to be tested, shall also be reported in terms of grains per DSCF.

Source test results shall also include turbine fuel flow rate and generator output (MW) under which the test was conducted.

Emission data shall be expressed in terms of lbs/MM cubic feet.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 10-20-2000; RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 10-20-2000]

[Devices subject to this condition: D1, D8, D15, D22]

57-1. The operator shall vent this equipment to the CO oxidation and SCR control whenever the turbine is in operation.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 10-20-2000; RULE 1303(b)(1)-Modeling, 5-10-1996; RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 10-20-2000; RULE 2005, 4-9-1999]

Section H
Facility I.D.:

Page: 18 127381 DRAFT

Revision #: DRAFT Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

63-1. The operator shall limit emissions from this equipment as follows

CONTAMINANT	EMISSIONS LIMIT					
СО	Less than or equal to 1267 LBS IN ANY ONE MONTH					
PM10	Less than or equal to 595 LBS IN ANY ONE MONTH					
VOC	Less than or equal to 243 LBS IN ANY ONE MONTH					
SOX	Less than or equal to 310 LBS IN ANY ONE MONTH					

The operator shall calculate the emission limit(s) using monthly fuel usage and the following emission factors: PM10 6.731 lb/mmcf, VOC 2.749 lb/mmcf and SOx 3.508 lb/mmcf

The operator shall calculate the emission limit(s) for the compliance with the monthly CO emission limit through valid CEMS data. In absence of valid CEMS data, the operator shall calculate the monthly CO emissions using monthly fuel use data and the following emission factor: CO 14.31 lbs/mmcf

For the purposes of this condition, the limit(s) shall be based on the total combined facility emissions.

[RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 10-20-2000]

[Devices subject to this condition: D1, D8, D15, D22]

67-1. The operator shall keep records, in a manner approved by the District, for the following parameter(s) or item(s):

Fuel use during commissioning period

[RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 10-20-2000; RULE 2012, 12-7-1995; RULE 2012, 3-16-2001]

Section H Page: 19
Facility I.D.: 127381
Revision #: DRAFT
Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

73-1. The operator may, at his discretion, choose not to use ammonia injection if any of the following requirement(s) are met::

the inlet temperature to the SCR reactor is 800 Degrees F or less, not to exceed 10 minutes during start-ups

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 10-20-2000]

[Devices subject to this condition: D1, D8, D15, D22]

82-1. The operator shall install and maintain a CEMS to measure the following parameters:

CO concentration in ppmv

Concentrations shall be corrected to 15 percent oxygen on a dry basis.

The CEMS will convert the actual CO concentrations to mass emission rates (lbs/hr) and record the hourly emission rates on a continuous basis.

The CEMS shall be installed , operated and maintained in accordance with an approved AQMD Rule 218 CEMS plan application. The operator shall not install CEMS prior to receiving the initial approval from AQMD

The CEMS shall be installed and operated to measure CO concentrations over a 15-minute averaging period

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 10-20-2000; RULE 1303(b)(1)-Modeling, 5-10-1996; RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 10-20-2000]

Section H Page: 20 Facility I.D.: Revision #:

127381 DRAFT April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

82-2. The operator shall install and maintain a CEMS to measure the following parameters:

NOX concentration in ppmv

The CEMS shall be installed and operating no later than 12 months after the initial start-up of the turbine. During the interim period between the initial start-up and the provisional certification date of the CEMS, the operator shall comply with the monitoring requirements of Rule 2012(h)(2) and 2012(h)(3). Within 2 weeks of the turbine start-up date, the operator shall provide written notification to the District of the exact start-up date

[RULE 2012, 12-7-1995; RULE 2012, 3-16-2001]

[Devices subject to this condition: D1, D8, D15, D22]

99-1. The 5 PPM NOX emission limit(s) shall not apply during commissioning and start-up periods. The commissioning period shall not exceed 25 hours per turbine. Start-up time shall not exceed 10minutes for each start-up. Written records of commissioning and start-ups shall be maintained and made available upon request from the Executive Officer.

[RULE 2005, 4-9-1999]

[Devices subject to this condition: D1, D8, D15, D22]

99-2. The 6 PPM CO emission limit(s) shall not apply during commissioning and start-up periods. The commissioning period shall not exceed 25 hours per turbine. The start-up time shall not exceed 10 minutes for each start-up. Written records of commissioning and start-ups shall be maintained and made available upon request from the Executive Officer.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 10-20-2000; RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 10-20-2000]

[Devices subject to this condition: D1, D8, D15, D22]

Section H Page: 21
Facility I.D.: 127381
Revision #: DRAFT
Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

99-3. The 195.58 LBS/MMCF NOX emission limit(s) shall only apply to report NOx emissions during start-up or during the commissioning period. Start-up time shall not exceed 10 minutes per start-up. The commissioning period shall not exceed 25 hours per turbine.

[RULE 2005, 4-9-1999]

[Devices subject to this condition: D1, D8, D15, D22]

144-1. The operator shall vent this equipment, during filling, only to the vessel from which it is being filled.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 10-20-2000]

[Devices subject to this condition: D29]

157-1. The operator shall install and maintain a pressure relief valve set at 20 psig.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 10-20-2000]

[Devices subject to this condition: D29]

179-1. For the purpose of the following condition number(s), continuously record shall be defined as recording at least once every hour and shall be calculated based upon the average of the continuous monitoring for that hour.

Condition Number 12-3

Condition Number 12-4

Condition Number 195-3

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 10-20-2000]

[Devices subject to this condition: C5, C12, C19, C26]

Section H Page: 22
Facility I.D.: 127381
Revision #: DRAFT
Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

179-2. For the purpose of the following condition number(s), continuously record shall be defined as recording at least once every month and shall be calculated based upon the average of the continuous monitoring for that month.

Condition Number 12-5

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 10-20-2000]

[Devices subject to this condition: C5, C12, C19, C26]

195-1. The 5 PPMV NOX emission limit(s) are averaged over 60 minutes at 15 percent O2 dry.

[RULE 2005, 4-9-1999]

[Devices subject to this condition: D1, D8, D15, D22]

195-2. The 6 PPMV CO emission limit(s) are averaged over 60 minutes at 15 percent O2 dry.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 10-20-2000; RULE 1303(b)(2)-Offset, 5-10-1996; RULE 1303(b)(2)-Offset, 10-20-2000]

[Devices subject to this condition: D1, D8, D15, D22]

195-3. The 5 PPMV NH3 emission limit(s) are averaged over 60 mins at 15 percent O2 dry. The operator shall calculate and continuously record the NH3 slip concentration using the following: NH3(ppmv)=[a-(b*c/1000000)]*(1000000/b), where a=NH3 injection rate(lb/hr)/17(lb/lbmole), b=dry exhaust gas flow rate(lb/hr)/29(lb/lbmole) and c=change in measured NOx across the SCR (ppmvd at stack O2). The operator shall install and maintain a NOx analyzer to measure the SCR inlet NOx ppmv accurate to plus or minus 5 percent and calibrated at least once every 12 months.

[RULE 1303(a)(1)-BACT, 5-10-1996; RULE 1303(a)(1)-BACT, 10-20-2000]

[Devices subject to this condition: C5, C12, C19, C26]

Section H Facility I.D.:

127381

Revision #: Date:

#: DRAFT April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

SECTION H: PERMIT TO CONSTRUCT AND TEMPORARY PERMIT TO OPERATE

The operator shall comply with the terms and conditions set forth below:

327-1. For the purpose of determining compliance with District Rule 475, combustion contaminant emissions may exceed the concentration limit or the mass emission limit listed, but not both limits at the same time.

[RULE 475, 10-8-1976; RULE 475, 8-7-1978]

[Devices subject to this condition: D1, D8, D15, D22]

419-1. To ensure compliance with Rule 1303 (b)(1) - Modeling, the combined total emissions from turbines 1, 2, 3 and 4 (Devices D1, D8, D15 and D22) shall not exceed the following:

Pollutant	Emission Limit
NOX	Less than or equal to 14.08 LBS PER HOUR

[RULE 2005, 4-9-1999]

[Devices subject to this condition: D1, D8, D15, D22]

Section I Page 1
Facility I.D.#: 127381
Revision #: DRAFT
Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

SECTION I: COMPLIANCE PLANS & SCHEDULES

NONE

Section J Page: 1
Facility I.D.: 127381
Revision #: DRAFT
Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

SECTION J: AIR TOXICS

NOT APPLICABLE

Section K Page: 1
Facility I.D.: 127381
Revision #: DRAFT
Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

SECTION K: TITLE V Administration

GENERAL PROVISIONS

- 1. This permit may be revised, revoked, reopened and reissued, or terminated for cause, or for failure to comply with regulatory requirements, permit terms, or conditions. [3004(a)(7)(C)]
- 2. This permit does not convey any property rights of any sort or any exclusive privilege. [3004(a)(7)(E)]

Permit Renewal and Expiration

- This permit shall expire five years from the date that the initial Title V permit is issued. The operator's right to operate under this permit terminates at midnight on this date, unless the facility is protected by an application shield in accordance with Rule 3002(b), due to the filing of a timely and complete application for a Title V permit renewal, consistent with Rule 3003. [3004(a)(2)]
- 4. To renew this permit, the operator shall submit to the Executive Officer an application for renewal at least 180 days, but not more than 545 days, prior to the expiration date of this permit. [3003(a)(6)]

Duty to Provide Information

5. The applicant for, or holder of, a Title V permit shall furnish, pursuant to Rule 3002(d) and (e), timely information and records to the Executive Officer or designee within a reasonable time as specified in writing by the Executive Officer or designee. [3004(a)(7)(F)]

Payment of Fees

6. The operator shall pay all required fees specified in Regulation III - Fees. [3004(a)(7)(G)]

Reopening for Cause

- 7. The Executive Officer will reopen and revise this permit if any of the following circumstances occur:
 - (A) Additional regulatory requirements become applicable with a remaining permit term of three or more years. Reopening is not required if the effective date of the requirement is later than the expiration date of this permit, unless the permit or any of its terms and conditions has been extended pursuant to paragraph (f)(4) and subdivision (i) [eliminate latter reference after Rule 3004 amendment] of Rule 3004.
 - (B) The Executive Officer or EPA Administrator determines that this permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of this permit.
 - (C) The Executive Officer or EPA Administrator determines that the permit must be revised or revoked to assure compliance with the applicable

Section K Page: 2
Facility I.D.: 127381
Revision #: DRAFT
Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

SECTION K: TITLE V Administration

requirements. [3005(g)(1)]

COMPLIANCE PROVISIONS

- 8. The operator shall comply with all regulatory requirements, and all permit terms and conditions, except:
 - (A) As provided for by the emergency provisions of condition no. 17 or condition no. 18, or
 - (B) As provided by an alternative operating condition granted pursuant to a federally approved (SIP-approved) Rule 518.2.

Any non-compliance with any federally enforceable permit condition constitutes a violation of the Federal Clean Air Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or revision; or denial of a permit renewal application. Non-compliance may also be grounds for civil or criminal penalties under the California State Health and Safety Code. [3004(a)(7)(A)]

- 9. The operator shall allow the Executive Officer or authorized representative, upon presentation of appropriate credentials to:
 - (A) Enter the operator's premises where emission-related activities are conducted, or records are kept under the conditions of this permit;
 - (B) Have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit;
 - (C) Inspect at reasonable times, any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under the permit; and
 - (D) Sample or monitor at reasonable times, substances or parameters for the purpose of assuring compliance with the facility permit or regulatory requirements. [3004(a)(10)(B)]
- 10. All terms and conditions in this permit, including any provisions designed to limit a facility's potential to emit, are enforceable by the EPA Administrator and citizens under the federal Clean Air Act, unless the term or condition is designated as not federally enforceable. Each day during any portion of which a violation occurs is a separate offense. [3004(g)]
- 11. A challenge to any permit condition or requirement raised by EPA, the operator, or any other person, shall not invalidate or otherwise affect the remaining portions of this permit. [3007(b)]
- 12. The filing of any application for a permit revision, revocation, or termination, or a notification of planned changes or anticipated non-compliance does not stay

Section K Page: 3
Facility I.D.: 127381
Revision #: DRAFT
Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

SECTION K: TITLE V Administration

any permit condition. [3004(a)(7)(D)]

- 13. It shall not be a defense for a person in an enforcement action, including those listed in Rule 3002(c)(2), that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit, except as provided for in "Emergency Provisions" of this section. [3004(a)(7)(H)]
- 14. The operator shall not build, erect, install, or use any equipment, the use of which, without resulting in a reduction in the total release of air contaminants to atmosphere, reduces or conceals an emission which would otherwise constitute a violation of Chapter 3 (commencing with Section 41700) of Part 4, of Division 26 of the California Health and Safety Code or of AQMD rules. This rule shall not apply to cases in which the only violation involved is of Section 48700 of the California Health and Safety Code, or Rule 402 of AQMD Rules. [408]
- 15. Nothing in this permit or in any permit shield can alter or affect:
 - (A) Under Section 303 of the federal Clean Air Act, the provisions for emergency orders;
 - (B) The liability of the operator for any violation of applicable requirements prior to or at the time of permit issuance;
 - (C) The applicable requirements of the Acid Rain Program, Regulation XXXI;
 - (D) The ability of EPA to obtain information from the operator pursuant to Section 114 of the federal Clean Air Act;
 - (E) The applicability of state or local requirements that are not "applicable requirements", as defined in Rule 3000, at the time of permit issuance but which do apply to the facility, such as toxics requirements unique to the State; and
 - (F) The applicability of regulatory requirements with compliance dates after the permit issuance date. [3004(c)(3)]
- 16. For any portable equipment that requires an AQMD or state permit or registration, excluding a) portable engines, b) military tactical support equipment and c) AQMD-permitted portable equipment that are not a major source, are not located at the facility for more than 12 consecutive months after commencing operation, and whose operation does not conflict with the terms or conditions of this Title V permit: 1) the facility operator shall keep a copy of the AQMD or state permit or registration; 2) the equipment operator shall comply with the conditions on the permit or registration and all other regulatory requirements; and 3) the facility operator shall treat the permit or registration as a part of its Title V permit, subject to recordkeeping, reporting and certification requirements. [3004(a)(1)]

Section K Page: 4
Facility I.D.: 127381
Revision #: DRAFT
Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

SECTION K: TITLE V Administration

EMERGENCY PROVISIONS

- 17. An emergency¹ constitutes an affirmative defense to an action brought for non-compliance with a technology-based emission limit only if:
 - (A) Properly signed, contemporaneous operating records or other credible evidence demonstrate that:
 - (1) An emergency occurred and the operator can identify the cause(s) of the emergency;
 - (2) The facility was operated properly (i.e. operated and maintained in accordance with the manufacturer's specifications, and in compliance with all regulatory requirements or a compliance plan), before the emergency occurred;
 - (3) The operator took all reasonable steps to minimize levels of emissions that exceeded emissions standard, or other requirements in the permit; and,
 - (4) The operator submitted a written notice of the emergency to the AQMD within two working days of the time when the emissions limitations were exceeded due to the emergency. The notice shall contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken; and
 - (B) The operator complies with the breakdown provisions of Rule 430 Breakdown Provisions, or subdivision (i) of Rule 2004 Requirements, whichever is applicable. [3002(g); 430, 2004(i)]
- 18. The operator is excused from complying with any regulatory requirement that is suspended by the Executive Officer during a state of emergency or state of war emergency, in accordance with Rule 118 Emergencies. [118]

^{1 &}quot;Emergency" means any situation arising from sudden and reasonably unforeseeable events beyond the control of the operator, including acts of God, which: (A) requires immediate corrective action to restore normal operation; and (B) causes the facility to exceed a technology-based emission limitation under the permit, due to unavoidable increases in emissions attributable to the emergency; and (C) is not caused by improperly designed equipment, lack of preventative maintenance, careless or imporper operation, or operator error.

Section K Page: 5
Facility I.D.: 127381
Revision #: DRAFT
Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

SECTION K: TITLE V Administration

RECORDKEEPING PROVISIONS

- 19. In addition to any other recordkeeping requirements specified elsewhere in this permit, the operator shall keep records of required monitoring information, where applicable, that include:
 - (A) The date, place as defined in the Title V permit, and time of sampling or measurements;
 - (B) The date(s) analyses were performed;
 - (C) The company or entity that performed the analyses;
 - (D) The analytical techniques or methods used;
 - (E) The results of such analyses; and
 - (F) The operating conditions as existing at the time of sampling or measurement. [3004(a)(4)(B)]
- 20. The operator shall maintain records pursuant to Rule 109 and any applicable material safety data sheet (MSDS) for any equipment claimed to be exempt from a written permit by Rule 219 based on the information in those records. [219(0)]
- 21. The operator shall keep all records of monitoring data required by this permit or by regulatory requirements for a period of at least five years from the date of the monitoring sample, measurement, report, or application. [3004(a)(4)(E)]

REPORTING PROVISIONS

- 22. The operator shall comply with the following requirements for prompt reporting of deviations:
 - (A) Breakdowns shall be reported as required by Rule 430 Breakdown Provisions or Subdivision (i) of Rule 2004 Requirements, whichever is applicable.
 - (B) Other deviations from permit or applicable rule emission limitations, equipment operating conditions, or work practice standards, determined by observation or by any monitoring or testing required by the permit or applicable rules that result in emissions greater than those allowed by the permit or applicable rules shall be reported within 72 hours (unless a shorter reporting period is specified in an applicable State or Federal Regulation) of discovery of the deviation by contacting AQMD enforcement personnel assigned to this facility or otherwise calling (800) CUT-SMOG.

Section K Page: 6
Facility I.D.: 127381
Revision #: DRAFT
Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

SECTION K: TITLE V Administration

- (C) A written report of such deviations reported pursuant to (B), and any corrective actions or preventative measures taken, shall be submitted to AQMD, in an AQMD approved format, within 14 days of discovery of the deviation.
- (D) All other deviations shall be reported with the monitoring report required by condition no. 23. [3004(a)(5)]
- 23. Unless more frequent reporting of monitoring results are specified in other permit conditions or in regulatory requirements, the operator shall submit reports of any required monitoring to the AQMD at least twice per year. The report shall include a) a statement whether all monitoring required by the permit was conducted; and b) identification of all instances of deviations from permit or regulatory requirements. A report for the first six calendar months of the year is due by August 31 and a report for the last six calendar months of the year is due by February 28. [3004(a)(4)(F)]
- 24. The operator shall submit to the Executive Officer and to the Environmental Protection Agency (EPA), an annual compliance certification. For RECLAIM facilities, the certification is due when the Annual Permit Emissions Program (APEP) report is due and shall cover the same reporting period. For other facilities, the certification is due on March 1 for the previous calendar year. The certification need not include the period preceding the date the initial Title V permit was issued. Each compliance certification shall include:
 - (A) Identification of each permit term or condition that is the basis of the certification;
 - (B) The compliance status during the reporting period;
 - (C) Whether compliance was continuous or intermittent;
 - (D) The method(s) used to determine compliance over the reporting period and currently, and
 - (E) Any other facts specifically required by the Executive Officer to determine compliance.

The EPA copy of the certification shall be sent to: Director of the Air Division Attn: Air -3 USEPA, Region IX 75 Hawthorne St. San Francisco, CA 94105 [3004(a)(10)(E)]

25. All records, reports, and documents required to be submitted by a Title V operator to AQMD or EPA shall contain a certification of accuracy consistent with Rule 3003(c)(7) by a responsible official (as defined in Rule 3000). [3004(a)(12)]

Section K Page: 7
Facility I.D.: 127381
Revision #: DRAFT
Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

SECTION K: TITLE V Administration

PERIODIC MONITORING

All periodic monitoring required by this permit pursuant to Rule 3004(a)(4)(c) is based on the requirements and justifications in the AQMD document "Periodic Monitoring Guidelines for Title V Facilities" or in case-by-case determinations documented in the Title V application file. [3004(a)(4)]

Section K Facility I.D.: 127381 Revision #: DRAFT April 19, 2001

Date:

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

SECTION K: TITLE V Administration

FACILITY RULES

This facility is subject to the following rules and regulations:

With the exception of Rule 402, 473, 477, 1118 and Rules 1401 through 1420, the following rules that are designated as non-federally enforceable are pending EPA approval as part of the state implementation plan. Upon the effective date of that approval, the approved rule(s) will become federally enforceable, and any earlier versions of those rules will no longer be federally enforceable.

RULE SOURCE	Adopted/Amended Date	FEDERAL Enforceability
RULE 1113	5-14-1999	Federally enforceable
RULE 1171	10-8-1999	Non federally enforceable
RULE 1171	6-13-1997	Federally enforceable
RULE 1303(a)(1)-BACT	5-10-1996	Federally enforceable
RULE 1303(b)(1)-Modeling	5-10-1996	Federally enforceable
RULE 1303(b)(2)-Offset	5-10-1996	Federally enforceable
RULE 2005	4-9-1999	Federally enforceable
RULE 2012	12-7-1995	Federally enforceable
RULE 2012	3-16-2001	Non federally enforceable
RULE 3004(a)(4)-Periodic Monitoring	12-12-1997	Non federally enforceable
RULE 3004(a)(4)-Periodic Monitoring	8-11-1995	Federally enforceable
RULE 401	3-2-1984	Federally enforceable
RULE 401	9-11-1998	Non federally enforceable
RULE 407	4-2-1982	Federally enforceable
RULE 409	8-7-1981	Federally enforceable
RULE 475	10-8-1976	Federally enforceable
RULE 475	8-7-1978	Non federally enforceable
40CFR 60 Subpart GG	3-6-1981	Federally enforceable

Appendix A Page 1 Facility I.D.#: 127381 Revision #: DRAFT Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

APPENDIX A: NOX AND SOX EMITTING EQUIPMENT EXEMPT FROM WRITTEN PERMIT PURSUANT TO RULE 219

NONE

Appendix B Page 1 Facility 1.D.#: 127381 Revision #: DRAFT Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

APPENDIX B: RULE EMISSION LIMITS [RULE 1113 5-14-1999]

- (1) Except as provided in paragraphs (c)(2), (c)(3), (c)(4), and specified coatings averaged under (c)(6) of Rule 1113, the operator shall not supply, sell, offer for sale, manufacture, blend, or repackage any architectural coating for use in the District which, at the time of sale or manufacture, contains more than 250 grams of VOC per liter of coating (2.08 pounds per gallon), less water, less exempt compounds, and less any colorant added to tint bases, and no person shall apply or solicit the application of any architectural coating within the District that exceeds 250 grams of VOC per liter of coating as calculated in this paragraph.
- (2) Except as provided in paragraphs (c)(3), (c)(4), and designated coatings averaged under (c)(6) of Rule 1113, the operator shall not supply, sell, offer for sale, manufacture, blend, or repackage, for use within the District, any architectural coating listed in the Table of Standards which contains VOC (excluding any colorant added to tint bases) in excess of the corresponding VOC limit specified in the table, after the effective date specified, and no person shall apply or solicit the application of any architectural coating within the District that exceeds the VOC limit as specified in this paragraph. No person shall apply or solicit the application within the District of any industrial maintenance coatings for residential use; or of any rust-preventative coating for industrial use.

Appendix B Page 2 Facility I.D.#: 127381 Revision #: DRAFT Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

APPENDIX B: RULE EMISSION LIMITS [RULE 1113 5-14-1999]

TABLE OF STANDARDS VOC LIMITS

Grams of VOC Per Liter of Coating, Less Water And Less Exempt Compounds

COATING	Limit*	Effective							
		1/1/1998	1/1/1999	5/14/99	7/1/2001	7/1/2002	1/1/2005	7/1/2006	7/1/2008
Bond Breakers	350								
Chemical Storage Tank Coatings	420							100	
Clear Wood Finishes									
Varnish	350						·		
Sanding Sealers	350								
Lacquer	680	550					275		
Concrete-Curing Compounds	350								
Dry-Fog Coatings	400								
Essential Public Service Coating	420		i			340		100	
Fire-proofing Exterior Coatings	450		350						
Fire-Retardant Coatings									
Clear	650								
Pigmented	350								
Flats	250				100				50
Floor Coatings	420					100		50	
Graphic Arts (Sign) Coatings	500								
High Temperature Industrial Maintenance Coatings						550		420	
Industrial Maintenance Coatings	420					250		100	
Japans/Faux Finishing Coatings	700		350						
Magnesite Cement Coatings	600		450						
Mastic Coatings	300								
Metallic Pigmented Coatings	500								
Multi-Color Coatings	420	250							
Non-Flat Coatings	250					150		50	
Pigmented Lacquer Pre-Treatment Wash	680	550					275		
Primers	780								
Primers, Sealers, and Undercoaters	350			_		200		100	
Quick-Dry Enamels	400					250		50	
Quick-Dry Primers, Sealers, and Undercoaters	350**					200		100	
Recycled Coatings				250		250		100	

Appendix B Page 3 Facility I.D.#: 127381 Revision #: DRAFT Date: April 19, 2001

FACILITY PERMIT TO OPERATE

ALLIANCE POWER INC

APPENDIX B: RULE EMISSION LIMITS [RULE 1113 5-14-1999]

Roof Coatings	300		T	250				
Roof Coatings Bituminous Roof	300					250		
Coatings								
Rust Preventative Coatings	420			400			100	
Shellac								
Clear	730							
Pigmented Specialty Primers	550							
Specialty Primers	350						100	
Stains	350					250		
Swimming Pool Coatings								
Repair	650							
Other	340							
Traffic Coatings Waterproofing Sealers Wood Concrete/Masonry	250	150						
Waterproofing Sealers								
Wood	400				1	250		
Concrete/Masonry	400							
Wood Preservatives	l							
Below-Ground	350							
Other	350							

^{*} The specified limits remain in effect unless revised limits are listed in subsequent columns in the Table of Standards

Grams of VOC Per Liter of Material

COATING

Limit

Low-Solids Coating

120

^{**} The specified limit applies unless the manufacturer submits a report pursuant to Rule 1113(g)(2).

Appendix B Page 4
Facility I.D.#: 127381
Revision #: DRAFT
Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

APPENDIX B: RULE EMISSION LIMITS [RULE 1171 10-8-1999]

Except as otherwise provided in Rule 1171, the operator shall not use a solvent to perform solvent cleaning unless the solvent complies with the applicable requirements set forth below:

		Cu	rrent limits	Effective 12/1/2001	Effective 7/1/2005
		VOC	VOC	VOC	VOC
SOL	VENT CLEANING	g/l	Composite	g/l	g/l
ACTI	VITY	(lb/gal)	Partial	(lb/gal)	(lb/gal)
			Pressure mm Hg @ 20°C (68°F)		
(A)	Product Cleaning				
	During Manufacturing		;		
	Process Or Surface				
	Preparation For				
	Coating, Adhesive, Or				
	Ink Application				
	(i) General	70		50	25
		(0.58)		(0.42)	(0.21)
	(ii) Electrical	900	33	500	100
	Apparatus	(7.5)		(4.2)	(0.83)
	Components &				
	Electronic				
	Components				
	(iii) Medical Devices &	900	33	800	800
	Pharmaceuticals	(7.5)		(6.7)	(6.7)
(B)	Repair and Maintenance				
	Cleaning				
	(i) General	50		50	25
		(0.42)		(0.42)	(0.21)
	(ii) Electrical	900	20	900	100
	Apparatus	(7.5)		(7.5)	(0.83)
	Components &				
	Electronic				
	Components				

Appendix B Page 5 Facility I.D.#: 127381 Revision #: DRAFT Date: April 19, 2001

FACILITY PERMIT TO OPERATE

ALLIANCE POWER INC

[RULE 1171 10-8-1999]

APPENDIX B: RULE EMISSION LIMITS

Effective Effective Current limits 12/1/2001 7/1/2005 VOC VOC VOC VOC SOLVENT CLEANING Composite g/1 g/1 g/l (lb/gal) Partial **ACTIVITY** (lb/gal) (lb/gal) Pressure mm Hg @ 20°C (68°F) Medical Devices 900 (iii) 33 & Pharmaceuticals (7.5)(I) Tools, 800 800 Equipment, & (6.7)(6.7)Machinery (II)General Work 600 600 Surfaces (5.0)(5.0)(C) Cleaning of Coatings, 950 35 550 25 or Adhesives (7.9)(4.6)(0.21)Application Equipment (D) Cleaning of Ink Application Equipment (i) General 100 3 50 25 (0.83)(0.42)(0.21)(ii) Flexographic 100 3 50 25 Printing (0.83)(0.42)(0.21)(iii) Gravure Printing (I) Publication 25 750 900 100 (7.5)(6.3)(0.83)(II) Packaging 100 3 50 25 (0.83)(0.42)(0.21)(iv) Lithographic or Letter Press Printing (I) Roller Wash -100 900 10 600 Step 1 (5.0)(0.83)

Appendix B Page 6
Facility I.D.#: 127381
Revision #: DRAFT
Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

APPENDIX B: RULE EMISSION LIMITS [RULE 1171 10-8-1999]

	ı			
			Effective	Effective
	Cu	rrent limits	12/1/2001	7/1/2005
	VOC	VOC	VOC	VOC
SOLVENT CLEANING	g/l	Composite	g/l	g/l
ACTIVITY	(lb/gal)	Partial	(lb/gal)	(lb/gal)
		Pressure mm Hg @ 20°C (68°F)		, <u>-</u> ,
(II) Roller Wash-				
Step 2, Blanket	900	10	800	100
Wash, & On-			(6.7)	(0.83)
Press		į		
Components				
(III) Removable	İ		50	25
Press			(0.42)	(0.21)
Components				
(v) Screen Printing	1070	5	750	100
	(8.9)		(6.3)	(0.83)
(vi) Ultraviolet Ink				
Application	800	33	800	100
Equipment	(6.7)		(6.7)	(0.83)
(except screen			:	
printing)				
(vii) Specialty	810	21	600	100
Flexographic	(6.8)		(5.0)	(0.83)
Printing				
(E) Cleaning of Polyester	50		50	25
Resin Application	(0.42)		(0.42)	(0.21)
Equipment				

FACILITY PERMIT TO OPERATE

ALLIANCE POWER INC

APPENDIX B: RULE EMISSION LIMITS [RULE 1171 6-13-1997]

Except as otherwise provided in Rule 1171, the operator shall not use a solvent to perform solvent cleaning unless the solvent complies with the applicable requirements set forth below:

		CURRE	NT LIMITS	Effective 1/1/1999		
SOLVENT CLEANING ACTIVITY		VOC g/l (lb/gal)	VOC Composite Partial Pressure mm Hg @ 20°C (68°F)	VOC g/l (lb/gal)	VOC Composite Partial Pressure mm Hg @ 20°C (68°F)	
(A)	Product Cleaning During Manufacturing Process Or Surface Preparation For Coating, Adhesive, Or Ink Application		(30_1)		(000)	
	(i) General	70 (0.58)				
	(ii) Electronic Components or Medical Devices	900 (7.5)	33			
(B)	Repair and Maintenance Cleaning					
	(i) General	900 (7.5)	20	50 (0.42)		
	(ii) Electrical Apparatus Components	900 (7.5)	20			
	(iii) Medical Devices	900 (7.5)	33			
(C)	Cleaning of Coatings, or Adhesives Application Equipment	950 (7.9)	35			
(D)	Cleaning of Ink Application Equipment					
	(i) General	100 (0.83)	3	·		
	(ii) Flexographic or Gravure Printing	100 (0.83)	3			
· -	(iii) Lithographic or Letter Press Printing	900 (7.5)	25		10	
	(iv) Screen Printing	1070 (8.9)	5			
	(v) Ultraviolet Inks (except screen printing)	800 (6.7)	33			
	(vi) Specialty Flexographic Printing	810 (6.8)	21			

Appendix B Page 8
Facility I.D.#: 127381
Revision #: DRAFT
Date: April 19, 2001

FACILITY PERMIT TO OPERATE ALLIANCE POWER INC

APPENDIX B: RULE EMISSION LIMITS [RULE 1171 6-13-1997]

	CURRE	NT LIMITS	Effective 1/1/1999		
SOLVENT CLEANING ACTIVITY	VOC g/l (lb/gal)	VOC Composite Partial Pressure mm Hg @ 20°C (68°F)	VOC g/l (lb/gal)	VOC Composite Partial Pressure mm Hg @ 20°C (68°F)	
(E) Cleaning of Polyester Resin Application Equipment	50 (0.42)				
or		1			